15KV FEEDER CONDUITS ROUTING FROM RISER LOCATION TO WESTBOUND TUBE 4-5" C. ENCASED IN 2" CONCRETE
SEE NOTE 13 FOR CONTINUATION SEE DWG. E-4.03
PULL AND OFFSET (PULL BOX 'A') AT TUBE CEILING BEFORE GATE. SEE DETAIL 'B' DWG. E8-03
PATH TUBE
4-5" CONDUITS AT GARAGE EXHAUST PLENUM CEILING WITHOUT CONCRETE ENVELOPE SEE NOTE 12.
15KV CABLE PULL AND TRANSITION CLOSET
4-5" CONDUITS IN 2" CONCRETE FLOOR FILL WITHIN GARAGE EXHAUST PLENUM TUNNEL. SEE NOTE 10.
UP TO 108TH FL MER. SEE NOTE 8
PB
TOWER 1
FOR FUTURE SERVICE, TO TWTC: RUN 1-5" CONDUIT WITH 2" CONCRETE ENVELOPE HARD AGAINST STRUCTURE, FROM BEAM AT HIGH POINT OF DOWN RAMP CEILING. SEE NOTE 11
4-5" CONDUITS ENCLOSED IN 2" CONCRETE ENVELOPE HARD AGAINST CEILING STRUCTURE. SEE NOTE 11
15KV CABLE PULL & TRANSITION CLOSET. SEE PART PLAN "B" DWG. E3-04.
2-5" CONDUIT TO EMERGENCY GENERATOR ROOM. SEE PART PLANS ON DWG. E8-03
PULL BOX INSIDE HUNG CEILING BETWEEN BEAMS
1-5" CONDUIT ENCASED IN CONCRETE WITHIN HUNG CEILING CAVITY
UP TO 108TH FL MER. SEE NOTE 8
TOWER 2